

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

BOARD MEMBERS PRESENT: CANGEMI, CATALANO, COHEN, COLUCCIO, DAUBERGER, GOTTFRIED, LORENZ, MARCOVICI, MAZZEO, MILLER, MONTUORI, MONIZ, PANARIELLO, PESCATORE, XANTHOS, CHAIRMAN ZEC AND DIRECTOR MINTZ.

- | | | |
|--|-----------------|--|
| 44120 Gilston Electrical Contracting Corporation 338 East 95 th Street New York, NY 10128 | Approved | Sub. #02A0418 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | Riker's Island GMDC New Kitchen Queens, NY |
| 44121 Jemco Electrical Contractors, Inc. 21-71 Steinway Street Astoria, NY 11105 | Approved | Sub. #02A0419 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | CUNY Central Administrative Office 535 East 80 th Street New York, NY |
| 44122 Interphase Electric Corp. 165 Garfield Place Brooklyn, NY 11215 | Hold | Sub. #02A0420 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | Queens Borough OCME Building 82-68 164 th Street Queens, NY |
| 44123 GMA Electrical Corporation 267B McClean Avenue Staten Island, NY 10305 | Approved | Sub. #02A0421 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | Verizon 7701 Third Avenue Brooklyn, NY |
| 44124 E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City, NY 11101-5378 | Approved | Sub. #02A0422 |
| Requested approval for the electric service equipment proposed to be installed in the building at: | | Montefiore Medical Center 111 210 Street Bronx, NY |
| 44125 DiFazio Electric NY, Inc. 100 Milden Avenue Staten Island, NY 10301 | Approved | Sub. #02A0423 |

Requested approval for the electric service equipment proposed to be installed in the building at:

Verizon
360 Bridge Street
Brooklyn, NY

-1-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

- | | | | |
|-------|--|-----------------|---|
| 44126 | S.N. Tannor, Inc. 222-02 Merrick Boulevard Springfield Gardens, NY 11413 | Approved | Sub. #02A0424 |
| | Requested approval for the electric service equipment proposed to be installed in the building located at: | | PS 253Q 1307 Central Avenue Far Rockaway, NY |
| 44127 | Harley Electric Co., Inc. 1817 Unionport Road Bronx, NY 10462 | Approved | Sub. #02A0425 |
| | Requested approval for the electric service equipment proposed to be installed in the building located at: | | 315 West 57 th Street New York, NY |
| 44128 | Al's Best Electric Corp. 400 Lafayette Street-Suite #150 New York, NY 10003 | Approved | Sub. #02A0426 |
| | Requested approval for the electric service equipment proposed to be installed in the building located at: | | 162 Fifth Avenue New York, NY |
| 44129 | Forest Electric Corp. Two Penn Plaza New York, NY 10121 | Approved | Sub. #02A0427 |
| | Requested approval for the electric service equipment proposed to be installed in the building located at: | | 435 7 th Avenue New York, NY |
| 44130 | Mass Electric Construction Co. 150-50 14 th Road Whitestone, NY 11357 | Approved | Sub. #02A0428 |
| | Requested approval for the electric service equipment proposed to be installed in the building located at: | | Biltmore Theatre 261-65 West 47 th Street New York, NY |

44131 Five Star Electric Corp. Sub. #02A0429
101-32 101st Street
Ozone Park, NY 11416-2616 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

19 Rector Street
New York, NY

-2-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44132 R.M.T. Electric Corp. Sub. #02A0430
238-19 Braddock Avenue
Bellerose, NY 11426 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

Verizon
89-63 163rd Street
Jamaica, NY

44133 Jacoby Electric Corp. Sub. #02A0431
10-40 Borden Avenue
Long Island City, NY 11101 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

60 Hudson Street
New York, NY

44134 Jata Electrical Construction Corp. Sub. #02A0432
2 West 46th Street-Suite 706
New York, NY 10036 **Approved**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

Active Wear Retail Store
512 Broadway
New York, NY

44135 Ideal Electric & HVAC Co., Inc. Sub. #02A0433
235 India Street
Brooklyn, NY 11222 **Hold**

Requested approval for the electric
service equipment proposed to be
installed in the building located at:

Belfer Residence
885 Park Avenue
New York, NY

44136 P & H Electric Corp. d/b/a Sub. #02A0434
Mage Electrical Contractors
158 Perry Street
New York, NY 10014 **Hold**

Requested approval for the electric service equipment proposed to be installed in the building located at:

31 West 27th Street-3rd Floor
New York, NY

Sub. #02A0435

44137 Egg Electric Inc.
26 West 17th Street
New York, NY 10011-5710

Hold

Requested approval for the electric service equipment proposed to be installed in the building at:

Grand Concourse Plaza
Grand Concourse Service
2501-2525 Grand Concourse
Bronx, NY

-3-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44138 Egg Electric Inc.
26 West 17th Street
New York, NY 10011-5710

Approved

Requested approval for the electric service equipment proposed to be installed in the building at:

Sub. #02A0436

Grand Concourse Plaza
Fordham Service Entrance
2501-2525 Grand Concourse
Bronx, NY

44139 G.S.H. Electric, Inc.
491 East 166th Street
Bronx, NY 10456-5605

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

Sub. #02A0437

I.S. 278(K)
1925 Stuart Street
Brooklyn, NY

44140 J.A. Lee Electric Inc.
10-18 47th Road
Long Island City, NY 11101

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

Sub. #02A0438

999 Forest Avenue
Staten Island, NY

44141 C.M.S. Electrical Services Inc.
306 West 37th Street-11th Floor
New York, NY 10018

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

Sub. #020439

Pasta Break
243 West 42nd Street
New York, NY

44142 Dal Electrical Corporation
5910 11th Avenue
Brooklyn, NY 11219

Approved

Sub. #02A0440

Requested approval for the electric service equipment proposed to be installed in the building located at:

Parker Jewish Geriatric Institute
271-11 76th Avenue
Queens, NY

44143 H & L Electric Inc.
41-11 28th Street
Long Island City, NY 11101

Approved

Sub. #02A0441

Requested approval for the electric service equipment proposed to be installed in the building located at:

518 West 57th Street
New York, NY

-4-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44144 June Electric Corp.
11-19 49th Avenue
Long Island City, NY 11101

Approved

Sub. #02A0442

Requested approval for the electric service equipment proposed to be installed in the building located at:

144 West 18th Street
New York, NY

44145 Atlas-Acon Electric Service Corp.
283 Hudson Street
New York, NY 10013

Approved

Sub. #02A0443

Requested approval for the electric service equipment proposed to be installed in the building located at:

630 5th Avenue
New York, NY

44146 R. Gunzer Inc.
36-08 34th Street
Long Island City, NY 11106

Approved

Sub. #02A0444

Requested approval for the electric service equipment proposed to be installed in the building located at:

560 West 34th Street
New York, NY

44147 Metropolis Electric Corp.
14-22 Astoria Park South
Long Island City, NY 11102

Approved

Sub. #02A0445

Requested approval for the electric service equipment proposed to be installed in the building located at:

1160 Richmond Road
Staten Island, NY

Sub. #02A0446

44148 High-Rise Electric, Inc.
13-15 Jackson Avenue
Long Island City, NY 11101

Approved

Requested approval for the electric service equipment proposed to be installed in the building located at:

St. Moritz
50 Central Park West
New York, NY

Sub. #02A0447

44149 Northgate Electric Corporation
225 West 34th Street-Suite 901
New York, NY 10122

Approved

Requested approval for the electric service equipment proposed to be installed in the building at:

3201 Kings Highway
Brooklyn, NY

-5-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44150 MBS Electric Inc.
65-50 Fresh Meadow Lane
Flushing, NY 11365

Approved

Sub. #02A0448

Requested approval for the electric service equipment proposed to be installed in the building located at:

924 West End Avenue
New York, NY

44151 Matros Automated Electrical Construction Corp.
214 West 29th Street-Suite 1504
New York, NY 10001

Approved

Sub. #02A0449

Requested approval for the electric service equipment proposed to be installed in the building located at:

San Carlos Hotel
150 East 50th Street
New York, NY

44152 Citi-Wide Electrical Inc.
1702 8th Avenue
Brooklyn, NY 11215

Hold

Sub. #02A0450

Requested approval for the electric service equipment proposed to be installed in the building located at:

159-10 71st Street
Flushing, NY

44153 A.M.C. Electrical Service, Inc.
3819 Fort Hamilton Parkway
Brooklyn, NY 11218

Approved

Sub. #02A0451

Requested approval for the electric service equipment proposed to be installed in the building located at:

9 East 40th Street
New York, NY

44154 Sage Electrical Contracting
651 Willowbrook Road, Suite 201
Staten Island, NY 10314

Approved

Sub. #02A0452

Requested approval for the electric service equipment proposed to be installed in the building located at:

Buy Buy Baby
200 West 26th Street
New York, NY

44155 Mechanical Construction Systems Inc. d/b/a
Laurelton Electric
230-04 S. Conduit Avenue
Laurelton, NY 11413

Approved

Sub. #02A0453

Requested approval for the electric service equipment proposed to be installed in the building at:

350 East 82nd Street
New York, NY

-6-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44156 Laser Lite Electrical, Inc.
40 Gatton Street
Staten Island, NY 10309

One time approval, with signage

Requesting permission to leave as installed, separate disconnect means for a two family house with separate occupancies with no common area, in a building located at:

702 Bloomingdale Road
Staten Island, NY

44157 Laser Lite Electrical, Inc.
40 Gatton Street
Staten Island, NY 10309

One time approval, with signage

Requesting permission to leave as installed, separate disconnect means for two family houses with separate occupancies with no common area, in buildings located at:

561 & 563 Bloomingdale Road
Staten Island, NY

44158 Laser Lite Electrical, Inc.
40 Gatton Street
Staten Island, NY 10309

One time approval, with signage

Requesting permission to leave as installed, separate disconnect means for two family houses with separate occupancies with no common area, in buildings located at:

827 & 829 Rossville Ave
Staten Island, NY

44159 Testa Electric Co., Inc.
1443 61st Street
Brooklyn, NY 11219 **One time approval**

Requesting permission for an outdoor meter and switch, as per submitted photos, for a city park located at:

Austin Park
Hylan Blvd. & Edgewater St.
Staten Island, NY

44160 Adco Electrical Corporation
380 Chelsea Road
Staten Island, NY 10314 **One time approval**

Requesting permission to use flexible metal conduit (greenfield) in lieu of a glass-polyester barrier to isolate the service cables within the pull box, for an Advisory Board approved job (Calendar #43428), as per submitted Specifications, in a building located at:

Metropolitan Museum of Art
1000 Fifth Avenue
New York, NY

44161 Laszlo Bodak Engineer, P.C.
45 West 36th Street
New York, NY 10018 **One time approval**

Requesting permission for a seventh service switch, where one of the existing switches is for a fire pump, as per submitted specifications, in a building located at:

Dance Theatre Workshop
219 West 19th Street
New York, NY

-7-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44162 S.A.L Electric Corporation
69-63 75th Street
Middle Village, NY 11379 **Denied**

Requesting permission to use 1½" deep receptacle and switch boxes, in lieu of 2½" boxes, as the wall is only 1¾" thick, for 1353 apartments at twenty buildings located at:

Woodside Houses
Broadway and 50th Street
Queens, NY

44163 Landmark Facilities Group, Inc.
252 East Avenue
East Norwalk, CT 06855 **One time approval**

Requesting permission, in conjunction with a 600 amp to 1000 amp electrical service upgrade, to allow soffiting the ductwork to alleviate clearance problems, as per submitted specifications and drawings, in a building

Columbia University
President House
60 Morningside Drive

located at:

New York, NY

44164 Petrocelli Electric
22-09 Queens Plaza North
Long Island City, NY 11101-4008

One time approval, with cold domestic water pipe to be grounded through the grounding grid and grid to be 25 ohms or less to ground.

Requesting permission for a grounding grid, in substitution for the water main ground, as per submitted specifications and drawings, in a building located at:

Bear Stearns
383 Madison Avenue
New York, NY

44165 Excel Electrical Corp.
137 East 233rd Street
New York, NY 10470

One time approval

Requesting permission to leave as installed appliance circuits for very small studio and one bedroom apartments not having a specific dining room, and often only having a countertop and not having to install 20 amp circuits as per submitted specifications and apartment layouts, in a building located at:

321 W. 54th Street
New York, NY

44166 Lawless & Mangione Architects & Engineers, LLP
480 North Broadway
Yonkers, NY 10701-0870

Hold

Requesting permission to use maximum demand valves, in lieu of existing load calculations, in conjunction with the installation of new air conditioning loads, as per submitted specifications, drawings and demand load chart, in a building located at:

PS 115K
1500 East 92nd Street
Brooklyn, NY

-8-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44167 Columbia University
500 West 120th Street
New York, NY 10027

Denied

Requesting permission to run low-voltage audio, video and control cables using plenum cable via the buildings electric closets, as per submitted specifications and cable descriptions, in a building located at:

Columbia University
S.W. Mudd Building
New York, NY

44168 Marty Dorkin
Licensed Electrical Contractors
547 Coney Island Avenue

Brooklyn, NY 11218

One time approval

Requesting permission to use glastek as barriers in pullboxes containing wires from 2 points of entry, 120/208 and 277/480, as per submitted specifications, in a building located at:

406 West 31st Street
New York, NY

44169 Cosentini Associates Consulting Engineers
Two Pennsylvania Plaza
New York, NY 10121

One time approval

Requesting permission to replace existing motor generator sets feeding the elevator motors with SCR drives, where the cable and overcurrent device for multiple elevator feeders will be sized as per submitted methodology and calculations, in a building located at:

1345 Avenue of the Americas
Park Avenue Plaza
299 Park Avenue
New York, NY

44170 Urban Power and Lighting, Inc.
24-42 49th Street
Astoria, NY 11103

Denied

Requesting permission to install a service switch for a fire pump outside of the electrical room, in the nearest available space in the same room as the fire pump equipment, with galvanized conduit in 2" concrete, as there was no space in the existing electrical room, as per submitted sketch, in a building located at:

206 Spring Street
New York, NY

44171 G.S.H. Electric, Inc.
491 E. 166th Street
Bronx, NY 10456

Denied

Requesting permission to leave the existing 800 amp three phase service switches with dual fuses as they are, with the existing 350 amp one time fuses to be replaced with new 350 amp FRN (dual element) fuses, in conjunction with electrical work as per submitted drawing, in a building located at:

IS 278
1925 Stuart Street
Brooklyn, NY

-9-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44172 Corporate Electrical Technologies Inc.
2719 Grand Avenue
Bellmore, NY 11710

One time approval, with signage

Requesting permission to leave as installed a 200 amp service switch outside of the electrical room, as there was no more space within the room, for a new cell site on the roof, as per submitted drawings, in a building located at:

710 Morris Park Avenue
Bronx, NY

44173 Galaxy Tri-State Electric Inc.
211-07 Jamaica Avenue
Queens Village, NY 11428

One time approval, with signage

Requesting permission to leave as installed a second service switch in a room adjacent to the service room, as per submitted drawing, in a building located at:

75-44 Main Street
Queens, NY

44174 A to Z Electrical Contracting, Maintenance & Service Corp.
307 Seventh Avenue-Suite 507
New York, NY 10001

One time approval

Requesting permission to leave as installed 150 #12 wires and eight #1 wires in a 15' long trough, not exceeding 11% of the trough capacity, as per submitted specifications, sketch and cutsheet, in a building located at:

Commerce Bank
1350 Avenue of the Americas
New York, NY

44175 Sidney Electrical Contracting Inc.
1950 Coney Island Avenue
Brooklyn, NY 11223

One time approval

Requesting permission to utilize an existing 1¼" rigid conduit run in the elevator shaft, being rewired from DC power to AC power for the new elevator motor and controls in a building located at:

179 Broadway
New York, NY

44176 New York City Housing Authority
Technical Services Department
23-02 49th Avenue
Long Island City, NY 11101

One time approval, IMC or rigid conduit must be utilized without any junction or cable support boxes within the elevator shaft. Other jurisdictions may apply.

Requesting permission to use elevator shaft for EMT conduit for low voltage CCTV signaling cable and an electrical riser for power related equipment, as per submitted specifications in a building located at:

20 Catherine Slip
New York, NY

-10-

**ADVISORY BOARD CALENDAR
JULY 3, 2002**

44177 American Power Conversion Corporation
85 Rangeway Road
North Billerica, MA 01826

Approved

Sub. #02A0405

Requested approval for use in New York City of your PowerStruXure Power Distribution System for Computer Racks.

44178 Kim Lighting, Inc. Sub. #02A0406
16555 E. Gale Avenue
City of Industry, CA 91745 **Approved**

Requested approval for use in New York City of your Landscape Lighting Fixture 6000 Series, Model 6220.

44179 Lighting Collaborative, Inc. Sub. #02A0407
124 West 24th Street, Suite 6C
New York, NY 10011 **Approved**

Requested approval for use in New York City of your MultiLine Track Lighting System, Series ML 1000.

44180 Knoll Inc. Sub. #02A0413
329 Railroad Street
East Greenville, PA 18041 **Approved**

Requested approval for use in New York City of your Portable Office Task Light for A3 Office System, Model OXTLF.

44181 Jesco Lighting, Inc. Sub. #02A0414
50-30 71st Street
Woodside, NY 11377 **Approved**

Requested approval for use in New York City of your T4 Portable Fluorescent Lighting Fixtures, Models: SP-8, SP-12, SP-16, SP-20, SP-24 and SP-28 Series.

44182 Saunatec Inc. Sub. #02A0415
575 East Cokato Street
Cokato, MN 55321 **Approved**

Requested approval for use in New York City of your Sauna Heater, Models: Finnleo, Helo, Polar, Amerec and McCoy Series and Components.

44183 Selux Corporation
5 Lumen Lane
Highland, NY 12528
Denied Sub. #02A0416

Requested approval for use in New York City of your
Surface wall, Ceiling Mounted Lighting Fixture, Model: Diskus.

44184 Selux Corporation
5 Lumen Lane
Highland, NY 12528
Approved Sub. #02A0417

Requested approval for use in New York City of your
Extruded Linear Lighting Fixture, Model: M100.

44185 Knoll Inc.
329 Railroad Street
East Greenville, PA 18041
Approved Sub. #02A0454

Requested approval for use in New York City of your
Pre-wired Modular Components for Office Modular
Furniture A3 System.

Carry-overs:

| <u>Cal. #</u> | <u>Original Meeting Date</u> | <u>Disposition</u> |
|----------------------|-------------------------------------|---------------------------|
| 43653 | (1/23/02) | Approved |
| 43683 | (2/13/02) | Approved |
| 43823 | (3/13/02, Equipment) | Hold |
| 43838 | (4/10/02) | Approved |
| 44049 | (6/12/02) | Approved |
| 44098 | (6/12/02, Special permission) | Denied |
| 44106 | (6/12/02, Equipment) | Hold |
| 44118 | (6/12/02, Equipment) | Approved |
| 44119 | (6/12/02, Equipment) | Approved |

Note-Advisory Board approvals are specific to the condition and specification detailed in the request and should not be construed as precedent for other installations.